



Jim Doyle, Governor
Mary P. Burke, Secretary

July 12, 2007

KITTLESON'S INC.
JAMES KITTLESON
2401 27TH STREET
RICE LAKE WI 54868

Re: Description: SEWAGE TANKS, FIBERGLASS
Manufacturer: KITTLESON'S INC.
Product Name: NATURES STOP RV HOLDING TANK
Model Number(s): 235 (236 TOTAL GALLONS)
Product File No: 20070337

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of July 2012.

This approval supersedes the approval issued on December 15, 2005, under product file number 20020224.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20020224.

This approval is contingent upon compliance with the following stipulation(s):

- This product may only receive waste from recreational vehicles.
- The joints between the tank cover and the inlets and outlet fittings must be made airtight.
- The glass-fiber reinforced resin joint between the tank and cover must be of sufficient depth and width to provide a corrosion resistant barrier, and be at least as strong as the tank wall. It must be at least 7/32 inch thick and have a total overlay of at least four inches.
- When this tank is installed to receive wastewater from only recreational vehicles, the tank must be installed by either a licensed plumber or a holder of a servicing license issued pursuant to s. 146.20, Wis. Stats., and ch. NR 113, Wis. Admin. Code. All servicing and disposal of the contents from these tanks must be in accord with s. 146.20, Wis. Stats., and ch. NR 113, Wis. Admin. Code.
- This product may only be used as a POWTS holding component in campgrounds permitted by the Department of Health and Family Services under ch. HFS 178.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wisconsin.gov